

m Fire Station Officer

Panchkula

M/s Principal

GMSSSS SECTOR 26 PANCHKULA

Memo No. FS/2020/11 dated : 05/10/2020

Subject : **Approval of fire fighting scheme Under 15 mtrs. from the fire safety point of view for Group B- Educational Building at SECTOR 26 PANCHKULA of GMSSSS SECTOR TWENTY SIX PANCHKULA :**

Reference your Transaction Id 130792023000062 dated: 01/10/2020 on the subject cited above.

In case for the approval of fire fighting scheme has been examined by the team of Fire Station Officers, Panchkula. The means of escape and Fire Protection system were checked and found as per the National Building Code of India, Part- IV guidelines. Therefore the proposed fire fighting scheme is hereby approved as per following detail from the fire safety point of view with the following details:-

Owner Name	Floor Detail	Terrace Height of Last Livable Floor(In Meters)	Ground Coverage
BUILDING	GROUND	4.00 MTRS	1200 SQFT
Owner Name	Basement Level	Basement Area	Basement Remarks
	NIL	NIL	NIL

The proposed fire fighting scheme is approved as submitted in the building plan subject to the approval of building plan by the competent authority.

The approval of fire scheme by this office doesn't absolve the firm from his responsibility from all consequences, in case of fire due to any deficiencies or anything left out in the scheme submitted by you.

Overhead & underground water tanks provided for firefighting shall be so constructed in such a way that the domestic water tank shall filled from overflow of the fire Water tanks.

As soon as the installations of fire fighting arrangements are completed, the same may be got inspected/ tested and clearance should be obtained from this office.

If the infringement of Byelaws remains un-noticed the Authority reserves the right to amend the Plans/Fire Fighting Scheme as and when any such infringement comes to notice after giving an opportunity of being heard and the Authority shall stand indemnified against any claim on this account.

If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Chapter-III Section 11 Sub-Section 1 & 2 of Fire Act 2009 i.e. imprisonment for a term which may extend to three month or fine which may extend to five thousand rupees or both.

The staircase shall be made with the specified material enabling it non-slippery

If the gap between ceiling and false ceiling is more than 800 mm then upright sprinkler and detectors above false ceiling & pendant sprinkler below false ceiling shall be installed in the building

Remarks : - Application Updated



FSO Panchkula 05/10/2020  
Panchkula

Exercising the power of Director, Fire Services, Haryana

From Fire Station Officer

Panchkula

To M/s Principal

GMSSSS SEC 26 PANCHKULA

Memo No. FS/2020/8 dated : 05/10/2020

Subject : No objection Certificate 15 mtrs. and Above from the fire safety point of view for Group B- Educational Building at SECTOR 26 PANCHKULA of GMSSSS SEC TWENTY SIX PANCHKULA

Reference your letter no. 130792023000068 dated 05/10/2020 on the subject cited above.

Tower Name	Floor Detail	Height	Ground Coverage
School Building	Ground Floor	4	1260

Basement Level	Basement Area	Basement Remarks
nil	nil	

- 1) All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
- 2) The open set back area is not checked at our end as it shall be checked by concerned building authority/department.
- 3) If any lapse or non functioning of fire system will be the sole responsibility of the owner/occupier.
- 4) All the means of escape shall be kept free of all the type of obstruction all the time.
- 5) All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 6) NOC granted subject to condition that there is no violation in sanctioned building plan by virtue of which fire fighting scheme was approved.
- 7) This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 8) The owner/occupier shall strictly follow the other applicable rules/by laws laid down regarding fire safety system. If you fail to comply with any of the above terms & conditions. This fire NOC will be deemed cancelled and you will be liable to be punish as per Fire Act 2009, chapter- 3, section- 31, sub-section 1 and 2.
- 9) If the infringements of Byelaws remains un-noticed the Authority reserves the right to amend the NOC as and when any such Infringements comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.

The above NOC is valid for only Five year from the date of issue of this letter Applying renewal of the same well in time shall be the responsibility of owner/occupier.

Remarks:- Application Updated



Fire Station Officer,

Panchkula

Exercising the power of Director, Fire Services, Haryana



Digitally signed by PANKU  
KUMAR PRAJAPATI  
Date: 2020.10.08 16:03:44 +05'30  
Reason: Digital Verification